

Sean Howard Production, Inc.

ABSTRACT

Test Specimen: WA 100-Cashmere

Test Standard: ASTM E84-05


Test Date: February 09, 2007

Test Sponsor: Sean Howard Production, Inc.

Test Results:

FLAME SPREAD INDEX	=	15
SMOKE DEVELOPED INDEX	=	10
	=	N/A ft. Beyond Burners Centerline


This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Teodoro Alvarado Jr
E84 Operator

February 9, 2007

Reviewed and approved:



Stephanie Martinez-Diaz
Technical Writer

February 9, 2007